

Mooring Deployment Record

Project Name: <i>SOG Ambient Monitoring</i>	
Project Area: <i>SOG</i>	
Mooring Name: <i>SOGW</i>	Station Name: <i>SOGN-H</i>
Latitude: <i>49° 50.205</i>	Longitude: <i>124° 52.133</i>
Depth: <i>330</i>	Tide:
Mag. Declination:	Time Zone: <i>UTC</i>
Date: <i>0128</i>	Time: <i>07/08/2010</i>
Remarks:	

Recovery

Date:	Time:
Remarks:	

Instruments

Type	Serial #	Depth	Time In:	Time Out	Notes
<i>Baker</i>	<i>H8567</i>	<i>45</i>			
<i>SBE37</i>	<i>6027</i>	<i>46.6</i>			
<i>RCM11</i>	<i>564</i>	<i>48.2</i>			
<i>Sonde</i>	<i>024094 B1B</i>	<i>145</i>			
<i>WH 600</i>	<i>2273</i>	<i>280</i>	<i>#3694</i>	<i>only case from #2275 was used</i>	
<i>RBR</i>	<i>17084</i>	<i>320</i>			
<i>SBE37</i>	<i>3501</i>	<i>320</i>			

Releases

Release	Serial #	Range:	Release	Freq	Other
<i>AR191</i>	<i>16u</i>	<i>B533</i>	<i>B534</i>		

Pingers

Pinger	Serial #	Voltage	Freq
<i>Helle</i>	<i>8547</i>	<i>19.5</i>	<i>27</i>
<i>Helle</i>	<i>6397</i>	<i>20.3</i>	<i>27</i>

Flotation

Type	Serial #	Size	Colour	Type	Serial #	Size	Colour
<i>SB30</i>	<i>3007</i>	<i>30</i>					
<i>SB30</i>	<i>3012</i>	<i>30</i>					
<i>SS 28</i>	<i>M232</i>	<i>28</i>					
<i>SS 28</i>	<i>208</i>	<i>28</i>					

Juhász, Tamás

From: Ian Beliveau [beliveau@oceanetic.com]
Sent: August 10, 2010 9:29 AM
To: Juhász, Tamás
Subject: 2010 vector 57
Attachments: "Certification"

Hi Tom,

The sum of hours for the trip is 41. That includes prep the day before with the fab of 2 x RCM 11 batteries. This will be out from what you expected, especially since it was one day less, so we can talk. Normally we agree on a set hourly rate, could we boost that a bit?

The data is on a flash drive, can drop it by today. The RCM at SoGN didn't collect anything, not sure why. I did not have a spare dsu to test (will be on the list next time), but it could be that the main electronics is having a problem. There was no sign of leakage in the pressure housing that I could see, closer inspection will be needed. This is the one with big corrosion problems, and on recovery the dsu display was 12 words.

Lastly there are some possible time-sync issues:

- Microcats #3501 deployed at SoGN-H was synced to my watch (PDT) instead of UTC.

- My PC was used to program instruments and synced to UTC from the gps. It looked as though the day was not changed before deployment of SoGS though (so it was set to Aug 6th, not 7th). I checked the ADCP log and it has the correct date though... the RCM at SoGN will need to be checked and possibly corrected for this. I have the proper start time and date recorded so this is no problem.

This is one of those realizations that happens at the end of a long day. Was my mind playing tricks? Why was the ADCP fine? Anyway Sophie knows about this, and the notes are included as "readme.txt" in the instrument directory.

See you later,
Ian

05/09/2010

SBE 37.

□SBE 37-SM

S>ds

SBE37-SM V 2.6b SERIAL NO. 3501 01 Jan 1980 00:00:03

logging not started

sample interval = 900 seconds

samplenumbers = 0, free = 190650

do not transmit real-time data

output salinity with each sample

output sound velocity with each sample

store time with each sample

number of samples to average = 4

serial sync mode disabled

wait time after serial sync sampling = 30 seconds

internal pump not installed

temperature = 23.79 deg C

S>mmddyy=080610

S>hhmmss=1221□

□

□

□

0721□

215

S>ds

SBE37-SM V 2.6b SERIAL NO. 3501 06 Aug 2010 07:22:17

logging not started

sample interval = 900 seconds

samplenumbers = 0, free = 190650

do not transmit real-time data

output salinity with each sample

output sound velocity with each sample

store time with each sample

number of samples to average = 4

serial sync mode disabled

wait time after serial sync sampling = 30 seconds

internal pump not installed

temperature = 23.82 deg C

S>startddmmyy=06□□SBE 37-SM

S>1

?cmd S>ds

SBE37-SM V 2.6b SERIAL NO. 3501 06 Aug 2010 07:24:32

logging not started

sample interval = 900 seconds

samplenumbers = 0, free = 190650

do not transmit real-time data

output salinity with each sample

output sound velocity with each sample

store time with each sample

number of samples to average = 4

serial sync mode disabled

wait time after serial sync sampling = 30 seconds

internal pump not installed

temperature = 23.98 deg C

S>startddmmyy=060810

S>starthhmmss=100000

start time = 06 Aug 2010 10:00:00

S>ds

SBE37-SM V 2.6b SERIAL NO. 3501 06 Aug 2010 07:25:33

logging not started

sample interval = 900 seconds

samplenumbers = 0, free = 190650

do not transmit real-time data
output salinity with each sample
output sound velocity with each sample
store time with each sample
number of samples to average = 4
serial sync mode disabled
wait time after serial sync sampling = 30 seconds
internal pump not installed
temperature = 24.08 deg C
S>startlater
start time = 06 Aug 2010 10:00:00
□ý

README.txt

RCM11 564.

CAUTION

Synchronize the time tags of this instrument with the first reading time. The PC may have had the incorrect UTC day when the clocks were synced.

Ian Beliveau

RCM11

firstReading_564.txt

A.M.L. M-637 CONVERTER V001

00757 00000 00000 01023 00000 00005 S

First reading at 22:51:06 UTC Aug 6th, 2010, SoGN-H


PlanADCP (Basic) : [C:\Program Files\VRD Instruments\PlanADCP\sogn.txt]

File Settings View Help



ADVANCED settings changed.

Advanced



Proposed Setup:

Deployment Duration: 90 days
Ensemble Interval: 00:02:00.00
Salinity: 30 ppt
Temperature: 8 °C
Water Pings: 58
Number of Depth Cells: 23
Depth Cell Size: 2 m

Deployment Consequences

First Cell Range: 3.08 m
Last Cell Range: 47.08 m
Max Range: 49.74 m
Standard Deviation: 0.47 cm/s
Ensemble Size: 614 bytes
Storage Required: 37.94 MB
Power Usage: 889.41 Wh
Battery Pack Usage: 2.0

Notes

SOGN-H
s/n 3694, 600kHz w/ external housing and case from 2275

Workhorse Sentinel: 600 kHz/ High Res./ 2 Battery Packs/ Memory: 64 MB

adcpdeploy.txt

>>>>> Function starting 08/06/10 21:57:02 >>>>>

[BREAK Wakeup A]
WorkHorse Broadband ADCP Version 16.21
RD Instruments (c) 1996-2002
All Rights Reserved.
>TS100806215704
>CZ

Powering Down

>>>>> Function starting 08/06/10 21:57:28 >>>>>

[BREAK Wakeup A]
WorkHorse Broadband ADCP Version 16.21
RD Instruments (c) 1996-2002
All Rights Reserved.
>CR1

[Parameters set to FACTORY defaults]

>DEPLOY?

Deployment Commands:

RE ----- Recorder ErASE
RN ----- Set Deployment Name

WD = 111 100 000 ----- Data Out (Vel,Cor,Amp; PG,St,P0; P1,P2,P3)
WF = 0088 ----- Blank After Transmit (cm)
WN = 030 ----- Number of depth cells (1-128)
WP = 00045 ----- Pings per Ensemble (0-16384)
WS = 0200 ----- Depth Cell Size (cm)
WV = 175 ----- Mode 1 Ambiguity Vel (cm/s radial)

TE = 01:00:00.00 ----- Time per Ensemble (hrs:min:sec.sec/100)
TF = **/**/**, **: **: ** --- Time of First Ping (yr/mon/day, hour:min:sec)
TP = 01:20.00 ----- Time per Ping (min:sec.sec/100)
TS = 10/08/06,21:57:29 --- Time Set (yr/mon/day, hour:min:sec)

EA = +00000 ----- Heading Alignment (1/100 deg)
EB = +00000 ----- Heading Bias (1/100 deg)
ED = 00000 ----- Transducer Depth (0 - 65535 dm)
ES = 35 ----- Salinity (0-40 pp thousand)
EX = 11111 ----- Coord Transform (Xform: Type,Tilts,3 Bm,Map)
EZ = 1111101 ----- Sensor Source (C,D,H,P,R,S,T)

CF = 11111 ----- Flow Ctrl (EnsCyc;PngCyc;Binry;Ser;Rec)
CK ----- Keep Parameters as USER Defaults
CR # ----- Retrieve Parameters (0 = USER, 1 = FACTORY)
CS ----- Start Deployment

>SYSTEM?

System Control, Data Recovery and Testing Commands:

AC ----- Output Active Fluxgate & Tilt Calibration data
AF ----- Field calibrate to remove hard/soft iron error
AR ----- Restore factory fluxgate calibration data
AX ----- Examine compass performance
AZ ----- Zero pressure reading

CB = 811 ----- Serial Port Control (Baud; Par; Stop)
CP # ----- Polled Mode (0 = NORMAL, 1 = POLLED)
CZ ----- Power Down Instrument

FC ----- Clear Fault Log
FD ----- Display Fault Log

```

                                adcpdeploy.txt
OL ----- Display Features List

PA ----- Pre-Deployment Tests
PC1 ----- Beam Continuity
PC2 ----- Sensor Data
PS0 ----- System Configuration
PS3 ----- Transformation Matrices

RR ----- Recorder Directory
RF ----- Recorder Space used/free (bytes)
RY ----- Upload Recorder Files to Host

```

```

>TS?
TS = 10/08/06,21:57:31 --- Time Set (yr/mon/day,hour:min:sec)
>PS0

```

```

Instrument S/N: 3694
Frequency: 614400 HZ
Configuration: 4 BEAM, JANUS
Match Layer: 10
Beam Angle: 20 DEGREES
Beam Pattern: CONVEX
Orientation: UP
Sensor(s): HEADING TILT 1 TILT 2 TEMPERATURE
Temp Sens Offset: -0.28 degrees C

```

```

CPU Firmware: 16.21 [0]
Boot Code Ver: Required: 1.13 Actual: 1.13
DEMOM #1 Ver: ad48, Type: 1f
DEMOM #2 Ver: ad48, Type: 1f
PWRTIMG Ver: 85d3, Type: 4

```

```

Board Serial Number Data:
C0 00 00 02 FB B2 24 09 CPU727-2000-00H
77 00 00 02 FB 7B 6A 09 DSP727-2001-03G
A4 00 00 02 FB 8C 65 09 PIO727-3000-03C
F4 00 00 02 FB 8E 9D 09 REC727-1000-03E

```

```

>PA

```

PRE-DEPLOYMENT TESTS

CPU TESTS:

```

RTC.....PASS
RAM.....PASS
ROM.....PASS

```

RECORDER TESTS:

```

PC Card #0.....DETECTED
Card Detect.....PASS
Communication.....PASS
DOS Structure.....FAIL
Sector Test (short).....PASS
PC Card #1.....DETECTED
Card Detect.....PASS
Communication.....PASS
DOS Structure.....PASS
Sector Test (short).....PASS

```

DSP TESTS:

```

Timing RAM.....PASS
Demod RAM.....PASS
Demod REG.....PASS
FIFOS.....PASS

```

SYSTEM TESTS:

```

XILINX Interrupts... IRQ3 IRQ3 IRQ3 ...PASS
Receive Loop-Back.....PASS
Wide Bandwidth.....PASS

```

adcpdeploy.txt
Narrow Bandwidth.....PASS
RSSI Filter.....PASS
Transmit.....PASS
SENSOR TESTS:
H/W Operation.....***FAIL***
>PC2

Press any key to quit sensor display ...

Heading	Pitch	Roll	Up/Down	Attitude Temp	Ambient Temp	PRESSURE
105.760	-3.540	-25.400	Up	23.750C	24.470C	0.0 kPa

>RS

RS = 001,060 ----- REC SPACE USED (MB), FREE (MB)

>PC1

BEAM CONTINUITY TEST

When prompted to do so, vigorously rub the selected beam's face.

If a beam does not PASS the test, send any character to the ADCP to automatically select the next beam.

Collecting Statistical Data...

47 46 46 40

Rub Beam 1 = PASS

Rub Beam 2 = PASS

Rub Beam 3 = PASS

Rub Beam 4 = PASS

>CZ

Powering Down

>>>>> Function starting 08/06/10 21:59:08 >>>>>

[BREAK Wakeup A]

WorkHorse Broadband ADCP Version 16.21

RD Instruments (c) 1996-2002

All Rights Reserved.

>RE ErASE erasing...

Recorder erased.

>CZ

Powering Down

>>>>> Function starting 08/06/10 21:59:38 >>>>>

[BREAK Wakeup A]

WorkHorse Broadband ADCP Version 16.21

RD Instruments (c) 1996-2002

All Rights Reserved.

>RR

Recorder Directory:

Volume serial number for device #1 is c497-71b7

No files found.

Bytes used on device #1 = 0

Total capacity = 63680512 bytes

adcpdeploy.txt
Total bytes used = 0 bytes in 0 files
Total bytes free = 63680512 bytes

>
[BREAK Wakeup A]
WorkHorse Broadband ADCP Version 16.21
RD Instruments (c) 1996-2002
All Rights Reserved.
>CR1
[Parameters set to FACTORY defaults]
>CF11101
>EA0
>EB0
>ED3250
>ES30
>EX11111
>EZ1111101
>WA50
>WB0
>WD111100000
>WF88
>WN23
>WP58
>WS200
>WV175
>TE00:02:00.00
>TP00:02.00
>CK
[Parameters saved as USER defaults]
>The command CS is not allowed in this command file. It has been ignored.
>The following commands are generated by this program:
>CF?
CF = 11101 ----- Flow Ctrl (EnsCyc;PngCyc;Binry;Ser;Rec)
>CF11101
>RN SOGNH
>CS