

Mooring Deployment Record

Project Name: <u>Sag - Amp</u>	
Project Area: <u>Straight of Georgia</u>	
Mooring Name: <u>SOAN-K</u>	Station Name: <u>SOAN</u>
Latitude: <u>49 50.186</u>	Longitude: <u>124 50.245</u>
Depth: <u>322 datum = 329</u>	Tide: <u>Powell River + 3m</u>
Mag. Declination: <u>7</u>	Time Zone: <u>UTC</u>
Date: <u>August 3, 2011</u>	Time: <u>0120 UTC</u>
Remarks:	

Recovery

Date: <u>Nov 26, 2011</u>	Time: <u>0830</u>
Remarks:	

Instruments

Type	Serial #	Depth	Time In:	Time Out	Notes
Baker	718405	44			
SBE19+	6027	45.6			UTC
Rcm 11	39	47.2			
SBE16+	4196	144			Get Data cable extended
WH600	4026 3694	279			
RBR	17085	319			
SBE37	1537	325			

Releases

Release	Serial #	Range:	Release	Freq	Other Diag.
AR861	887	169C	1655	12kHz	1649

Pingers

Pinger	Serial #	Voltage	Freq
Helle	6393	19.9	27 kHz
Helle	7081	19.9	27 kHz

Flotation

Type	Serial #	Size	Colour	Type	Serial #	Size	Colour
SB30	3007	30"	yellow				
"	3005	"	"				
SS28	M1232	28"	"				
SS28	208	28"	"				

PST
 ↑
 I checked
 time and
 it was
 Local
 4P

Time 7
 must be
 local

Get Data cable extended
 Local
 Time

Diag.

```

SBE 19plus
S>*ds
SCP16, 6027, 2.0c, 5820, 3, 19, N
S>
S>ds
SBE 19plus V 2.0c SERIAL NO. 6027 06 Aug 2011 14:40:42
vbatt = 13.7, vlith = 8.7, ioper = 61.2 ma, ipump = 41.2 ma,
iext01 = 35.0 ma
status = not logging
sample interval = 1800 seconds, number of measurements per sample = 4
samples = 5820, free = 3457240
mode = moored, run pump during sample, delay before sampling = 5.0 seconds
transmit real-time = no
battery type = alkaline, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 508.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes
Ext Volt 2 = no, Ext Volt 3 = no
Ext Volt 4 = no, Ext Volt 5 = no
echo characters = yes
output format = raw HEX
S>note: I'm putting this in UTC
<ERROR type='INVALID COMMAND' msg='RCVD:note: i'm putting this in utc'/'>
S>date=080611
<ERROR type='INVALID COMMAND' msg='RCVD:date=080611'/'>
S>datetime=0608062011224025
S>ds
SBE 19plus V 2.0c SERIAL NO. 6027 06 Aug 2011 22:40:26
vbatt = 13.8, vlith = 8.7, ioper = 61.3 ma, ipump = 39.0 ma,
iext01 = 35.9 ma
status = not logging
sample interval = 1800 seconds, number of measurements per sample = 4
samples = 5820, free = 3457240
mode = moored, run pump during sample, delay before sampling = 5.0 seconds
transmit real-time = no
battery type = alkaline, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 508.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes
Ext Volt 2 = no, Ext Volt 3 = no
Ext Volt 4 = no, Ext Volt 5 = no
echo characters = yes
output format = raw HEX
S>ts
04F4270B33760828DC554E032A05D015D07FB5
S>outputformat=3
S>ts
22.7827, 0.01268, 0.047, 0.0593, 0.1126, 06 Aug 2011 22:42:21
S>ts
22.9855, 0.01232, 0.049, 4.9371, 4.2025, 06 Aug 2011 22:42:50
S>ts
23.1220, 0.01194, 0.054, 0.0612, 0.1134, 06 Aug 2011 22:43:16
S>ts
23.1934, 0.01149, 0.050, 4.9371, 4.9432, 06 Aug 2011 22:43:33
S>outputformat=1
S>ds
SBE 19plus V 2.0c SERIAL NO. 6027 06 Aug 2011 22:44:00

```

```

vbatt = 13.7, vlith = 8.7, ioper = 61.4 ma, ipump = 44.5 ma,
iext01 = 36.1 ma
status = not logging
sample interval = 1800 seconds, number of measurements per sample = 4
samples = 5820, free = 3457240
mode = moored, run pump during sample, delay before sampling = 5.0 seconds
transmit real-time = no
battery type = alkaline, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 508.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes
Ext Volt 2 = no, Ext Volt 3 = no
Ext Volt 4 = no, Ext Volt 5 = no
echo characters = yes
output format = converted HEX
S>initlogging=y
<ERROR type='INVALID COMMAND' msg='RCVD:initlogging=y'/>
S>initlogging
this command will change the scan length and/or initialize logging
repeat the command to verify
initlogging
S>ds
SBE 19plus V 2.0c SERIAL NO. 6027 06 Aug 2011 22:45:07
vbatt = 13.7, vlith = 8.7, ioper = 61.3 ma, ipump = 44.8 ma,
iext01 = 34.4 ma
status = not logging
sample interval = 1800 seconds, number of measurements per sample = 4
samples = 0, free = 3463060
mode = moored, run pump during sample, delay before sampling = 5.0 seconds
transmit real-time = no
battery type = alkaline, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 508.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes
Ext Volt 2 = no, Ext Volt 3 = no
Ext Volt 4 = no, Ext Volt 5 = no
echo characters = yes
output format = converted HEX
S>startlater[ ][ ][ ][ ]datetime=08072011010000
S>start[ ][ ][ ][ ]ds
SBE 19plus V 2.0c SERIAL NO. 6027 06 Aug 2011 22:46:07
vbatt = 13.7, vlith = 8.7, ioper = 61.2 ma, ipump = 45.7 ma,
iext01 = 35.0 ma
status = not logging
sample interval = 1800 seconds, number of measurements per sample = 4
samples = 0, free = 3463060
mode = moored, run pump during sample, delay before sampling = 5.0 seconds
transmit real-time = no
battery type = alkaline, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 508.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes
Ext Volt 2 = no, Ext Volt 3 = no
Ext Volt 4 = no, Ext Volt 5 = no
echo characters = yes
output format = converted HEX
S>startlater

```

start logging at = 07 Aug 2011 01:00:00, sample interval = 1800 seconds

32992

RCM 11 Deployment Sheet

Instrument Serial #: 39 # of Channels: 6 Recording Interval: 30 mins
 Project: SOAN-K DSU ID: 15059

Pressure Sensor:

Type: 3815C
 Range: ~~7000 kPa~~ 60 MPa
 Serial #: 730

Conductivity Cell:

Type: 3819
 Range: 24-38 mS
 Serial #: 24

Temperature Sensor:

Type: 3621
 Range: ~~Arctic Low~~
 Serial #: low

Doppler Current Sensor:

Type: SR10
 Serial #: 32

MAX DEPTH: 736m (7000kPa pressure sensor)

Channel #	Reading1	Reading 2	Last Cal
1. Reference	<u>652</u>		
2. Temperature	<u>0</u>		
3. Conductivity	<u>0</u>		
4. Extemp/pressure	<u>1023</u>		
5. Direction	<u>309</u>		
6. Speed	<u>31</u>		
Date: <u>Aug 7, 2011</u> Time: <u>2100 UTC</u>			

Channel #	Reading1	Reading 2	Last Cal
1. Reference	<u>652</u>		
2. Temperature	<u>324</u>		
3. Conductivity	<u>457</u>		
4. Extemp/pressure	<u>798</u>		
5. Direction	<u>904</u>		
6. Speed	<u>31</u>		
Date: <u>Nov 26, 2011</u> Time: <u>1731</u>			

TIME IN WATER: _____ DATE: August 8, 2011
 BAT VOLTAGE: 9.68 ON DEPLOYMENT
 CRUISE ID: 2011-60 DEPLOYED
 TECHNICIAN: LP

TIME OUT WATER: 0930 DATE: Nov 26, 2011
 BAT VOLTAGE: 7.9 ON RECOVERY
 CRUISE ID: 2011-76 RECOVERED
 TECHNICIAN: LP

NOTES:

Had to swap out cases because this was too long for cage CP. Obtained records - 5370
 expected - 5322

```
pump installedds  
SeacatPlus V 1.3a SERIAL NO. 4196    06 Aug 2011   15:16:14  
vbatt = 13.8, vlith = 8.7, ioper = 62.0 ma, ipump = 75.4 ma,  
iext01 = 9.6 ma,  
status = not logging  
sample interval = 4500 seconds, number of measurements per sample = 4  
samples = 2329, free = 439176  
mode = moored, run pump during sample, delay before sampling = 35.0 seconds  
transmit real-time = no  
battery type = ALKALINE, battery cutoff = 7.5 volts  
pressure sensor = strain gauge, range = 1450.0  
SBE 38 = no, Gas Tension Device = no  
Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = no, Ext Volt 3 = no  
echo commands = yes  
output format = raw HEX  
S>NOTE: This time is in local time and not UTC by Cindys say  
?cmd S>dmmmytc  
0.00910  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
0.00911  
stop 0.00912  
sto 0.00912  
pstop 0.00912  
stop 0.00912  
stop 0.00912  
0.00912  
0.00913  
0.00913  
0.00913  
0.00913  
0.00913  
0.00913  
^ 0.00913  
S>  
S>^^^ ^^ ^^^ stop  
S>ds  
SeacatPlus V 1.3a SERIAL NO. 4196    06 Aug 2011   15:18:00  
vbatt = 13.8, vlith = 8.7, ioper = 61.9 ma, ipump = 56.4 ma,  
iext01 = 11.5 ma,  
status = not logging  
sample interval = 4500 seconds, number of measurements per sample = 4  
samples = 2329, free = 439176  
mode = moored, run pump during sample, delay before sampling = 35.0 seconds
```

transmit real-time = no
battery type = ALKALINE, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 1450.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = no, Ext Volt 3 = no
echo commands = yes
output format = raw HEX
S>tv

0.0105	0.0000	0.0001	0.0000
4.3234	0.0001	0.0002	0.0000
4.6686	0.0001	0.0000	0.0000
4.1097	0.0000	0.0002	0.0000
4.7164	0.0000	0.0001	0.0000
4.7154	0.0000	0.0001	0.0001
3.7089	0.0000	0.0002	0.0001
0.0014	0.0000	0.0000	0.0000
0.0014	0.0000	0.0001	0.0000
0.0015	0.0000	0.0000	0.0000
0.0016	0.0000	0.0001	0.0000
0.0014	0.0000	0.0000	0.0000
0.0014	0.0000	0.0000	0.0000
0.0018	0.0000	0.0000	0.0000
0.0018	0.0000	0.0000	0.0000
0.0019	0.0003	0.0000	0.0000
0.0018	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0001
0.0022	0.0000	0.0000	0.0000
0.0023	0.0000	0.0002	0.0000
0.0023	0.0000	0.0001	0.0000
0.0023	0.0001	0.0001	0.0001
0.0023	0.0001	0.0000	0.0000
0.0021	0.0000	0.0000	0.0001
0.0024	0.0000	0.0001	0.0001
0.0025	0.0001	0.0000	0.0001
0.0025	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0002
0.0023	0.0000	0.0000	0.0001
0.0022	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0001	0.0001	0.0001
0.0021	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0025	0.0002	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0024	0.0002	0.0000	0.0001
0.0021	0.0000	0.0002	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0001
0.0021	0.0001	0.0003	0.0000
0.0023	0.0000	0.0000	0.0001
0.0021	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000

0.0022	0.0000	0.0000	0.0000
0.0021	0.0001	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0002	0.0003	0.0003
0.0022	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0022	0.0002	0.0000	0.0000
0.0024	0.0001	0.0001	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0002	0.0000
0.0024	0.0000	0.0001	0.0000
0.0021	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0001	0.0000
0.0023	0.0000	0.0000	0.0001
0.0024	0.0001	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0022	0.0000	0.0001	0.0000
0.0023	0.0002	0.0003	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0002	0.0000
0.0021	0.0000	0.0000	0.0000
0.0023	0.0000	0.0002	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0000	0.0001	0.0003
0.0022	0.0000	0.0001	0.0001
0.0021	0.0002	0.0001	0.0000
0.0024	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0023	0.0000	0.0001	0.0002
0.0022	0.0000	0.0000	0.0000
0.0027	0.0000	0.0003	0.0000
0.0023	0.0000	0.0003	0.0000
0.0023	0.0000	0.0001	0.0001
0.0025	0.0000	0.0000	0.0001
0.0022	0.0000	0.0000	0.0000
0.0024	0.0000	0.0001	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0002	0.0001	0.0000
0.0021	0.0000	0.0000	0.0001
0.0021	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0001
0.0022	0.0001	0.0000	0.0000
0.0024	0.0000	0.0001	0.0000
0.0025	0.0000	0.0000	0.0000
0.0023	0.0002	0.0000	0.0000
0.0022	0.0000	0.0000	0.0001

S>tv

0.0109	0.0000	0.0000	0.0000
0.0075	0.0000	0.0000	0.0000
0.4477	0.0000	0.0000	0.0000
4.0866	0.0000	0.0001	0.0000
4.7161	0.0000	0.0002	0.0000

4.7156	0.0000	0.0000	0.0001
3.8500	0.0000	0.0000	0.0000
0.0018	0.0000	0.0000	0.0000
0.0014	0.0001	0.0000	0.0005
0.0017	0.0000	0.0001	0.0001
0.0016	0.0000	0.0000	0.0000
0.0016	0.0000	0.0000	0.0000
0.0016	0.0000	0.0000	0.0000
0.0016	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0001
0.0022	0.0000	0.0001	0.0000
0.0024	0.0000	0.0001	0.0000
0.0020	0.0002	0.0001	0.0000
0.0022	0.0000	0.0000	0.0001
0.0025	0.0000	0.0000	0.0002
0.0022	0.0000	0.0002	0.0000
0.0025	0.0000	0.0001	0.0001
0.0019	0.0000	0.0001	0.0001
0.0022	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0024	0.0001	0.0001	0.0000
0.0023	0.0000	0.0001	0.0000
0.0019	0.0000	0.0000	0.0000
0.0023	0.0000	0.0001	0.0000
0.0021	0.0000	0.0001	0.0000
0.0020	0.0000	0.0000	0.0000
0.0022	0.0001	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000
0.0020	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0001
0.0022	0.0000	0.0001	0.0000
0.0019	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0002
0.0025	0.0000	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000
0.0023	0.0000	0.0001	0.0000
0.0023	0.0001	0.0000	0.0000
0.0024	0.0000	0.0000	0.0002
0.0026	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0023	0.0001	0.0002	0.0000
0.0020	0.0002	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0021	0.0000	0.0001	0.0000
0.0023	0.0000	0.0000	0.0001
0.0026	0.0001	0.0001	0.0000
0.0023	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0001	0.0000	0.0000

0.0023	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0024	0.0002	0.0000	0.0000
0.0021	0.0000	0.0000	0.0001
0.0023	0.0000	0.0000	0.0001
0.0022	0.0000	0.0000	0.0001
0.0025	0.0000	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0023	0.0001	0.0000	0.0000
0.0022	0.0000	0.0001	0.0000
0.0022	0.0000	0.0003	0.0000
0.0021	0.0000	0.0000	0.0001
0.0024	0.0000	0.0001	0.0000
0.0021	0.0000	0.0000	0.0000
0.0022	0.0000	0.0002	0.0000
0.0025	0.0000	0.0001	0.0000
0.0023	0.0000	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000
0.0021	0.0000	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000
0.0020	0.0000	0.0003	0.0000
0.0023	0.0000	0.0000	0.0000
0.0023	0.0001	0.0000	0.0000
0.0024	0.0000	0.0001	0.0000
0.0023	0.0000	0.0002	0.0000
0.0020	0.0000	0.0000	0.0000
0.0023	0.0000	0.0000	0.0000
0.0024	0.0000	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0024	0.0001	0.0000	0.0000
0.0022	0.0000	0.0000	0.0000
0.0023	0.0000	0.0001	0.0000
0.0022	0.0000	0.0000	0.0000
0.0021	0.0001	0.0000	0.0000
0.0025	0.0000	0.0000	0.0000
0.0021	0.0001	0.0001	0.0000
0.0022	0.0000	0.0002	0.0000
0.0023	0.0000	0.0002	0.0000

S>ds

SeacatPlus V 1.3a SERIAL NO. 4196 06 Aug 2011 15:19:03
 vbatt = 13.8, vlith = 8.7, ioper = 61.9 ma, ipump = 62.4 ma,
 iext01 = 10.3 ma,
 status = not logging
 sample interval = 4500 seconds, number of measurements per sample = 4
 samples = 2329, free = 439176
 mode = moored, run pump during sample, delay before sampling = 35.0 seconds
 transmit real-time = no
 battery type = ALKALINE, battery cutoff = 7.5 volts
 pressure sensor = strain gauge, range = 1450.0
 SBE 38 = no, Gas Tension Device = no
 Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = no, Ext Volt 3 = no
 echo commands = yes
 output format = raw HEX
 S>data␣etime=08062011151945
 ?cmd S>datetime=08062011152010
 ?cmd S>ds

SeacatPlus V 1.3a SERIAL NO. 4196 06 Aug 2011 15:20:46

```

vbatt = 13.8, vlith = 8.7, ioper = 61.9 ma, ipump = 55.7 ma,
iext01 = 11.1 ma,
status = not logging
sample interval = 4500 seconds, number of measurements per sample = 4
samples = 2329, free = 439176
mode = moored, run pump during sample, delay before sampling = 35.0 seconds
transmit real-time = no
battery type = ALKALINE, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 1450.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = no, Ext Volt 3 = no
echo commands = yes
output format = raw HEX
S>ds
SeacatPlus V 1.3a SERIAL NO. 4196 06 Aug 2011 15:21:02
vbatt = 13.8, vlith = 8.7, ioper = 61.9 ma, ipump = 60.6 ma,
iext01 = 10.6 ma,
status = not logging
sample interval = 4500 seconds, number of measurements per sample = 4
samples = 2329, free = 439176
mode = moored, run pump during sample, delay before sampling = 35.0 seconds
transmit real-time = no
battery type = ALKALINE, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 1450.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = no, Ext Volt 3 = no
echo commands = yes
output format = raw HEX
S>volt2=y
this command will change the scan length and initialize logging
proceed Y/N ? y
scan length has changed, initializing logging
S>volt3=y
this command will change the scan length and initialize logging
proceed Y/N ? y
scan length has changed, initializing logging
S>ds
SeacatPlus V 1.3a SERIAL NO. 4196 06 Aug 2011 15:21:32
vbatt = 13.8, vlith = 8.7, ioper = 61.9 ma, ipump = 59.8 ma,
iext01 = 10.8 ma, iext23 = 0.4 ma,
status = not logging
sample interval = 4500 seconds, number of measurements per sample = 4
samples = 0, free = 364722
mode = moored, run pump during sample, delay before sampling = 35.0 seconds
transmit real-time = no
battery type = ALKALINE, battery cutoff = 7.5 volts
pressure sensor = strain gauge, range = 1450.0
SBE 38 = no, Gas Tension Device = no
Ext Volt 0 = yes, Ext Volt 1 = yes, Ext Volt 2 = yes, Ext Volt 3 = yes
echo commands = yes
output format = raw HEX
S>startdatetime=08062011230000
?cmd S>startdatetime 080620011230000
?cmd S>startdata=08062011
?cmd S>startdate-080611
?cmd S>startdate=080611
?cmd S>ds

```

RDI 75/150/300/600 kHz Long Ranger/Workhorse

Project: SOCN-K
Serial Number: 3694
Cruise ID: 2011-60
Platform: Vector
Station: _____
Deployment Date: August 7, 2011
Recovery Date: _____
Position: _____
Depth: _____

Parameters:
Ensemble Interval: 5 mins
Bin Size: 2 m
Number of Pings: 103
Number of Bins: 29
Ambiguity Velocity: 0.30 cm/s
Water profiling Mode: wBo
Time: UTC
Start Time: August 7, 0100 UTC
Power: 900 wh
Battery Type: 2 x
Card size : 256 mbyte

PlanADCP (Advanced): Workhorse Sentinel 600 kHz [Dp11]

BackToSC Settings View Help

Basic Expert

Environmental Setup: Transducer Depth: 285 m Salinity: 32 ppt Magnetic Variation: 0 ° Temperature: 5 °C	Profiling Setup: Pings Per Ensemble: 103 Number of Depth Cells: 29 Depth Cell Size: 2 m Mode: 1	Deployment Consequences: First Cell Range: 2.98 m Last Cell Range: 58.98 m Max Range: 47.46 m Standard Deviation: 0.30 cm/s Ensemble Size: 728 bytes Storage Required: 25.16 MB Power Usage: 893.76 Wh Battery Pack Usage: 2.0
--	--	---

Deployment Timing Setup: Duration: 120 days Ensemble Interval: 00:05:00.00 Ping Int. (✓ Auto): 00:00:02.91 ☐ Ping Immediately After Deployment First Ping Date and Time: 06-Aug-2011 01:00:00 AM	Notes: 3694-SOQN-K Start: August 7, 0100UTC Batteries: 2x external
--	--

CR1
 CF11101
 EA0
 EB0
 ED2850
 ES32
 EX11111
 EZ1111111
 WB0
 WD111100000
 WF88
 WN29
 WP103
 WS200
 WV170
 TE00:05:00.00
 TP00:02.91
 TF11/08/07 01:00:00
 CK
 CS

>>>>>> Function starting 08/06/11 19:42:02 >>>>>>

[BREAK Wakeup A]
 WorkHorse Broadband ADCP Version 16.21
 RD Instruments (c) 1996-2002
 All Rights Reserved.

>TS110806194204
>CZ

Powering Down

>>>>> Function starting 08/06/11 19:42:08 >>>>>

[BREAK Wakeup A]

WorkHorse Broadband ADCP Version 16.21

RD Instruments (c) 1996-2002

All Rights Reserved.

>DEPLOY?

Deployment Commands:

RE ----- Recorder ErAsE

RN ----- Set Deployment Name

WD = 111 100 000 ----- Data Out (Vel,Cor,Amp; PG,St,P0; P1,P2,P3)

WF = 0088 ----- Blank After Transmit (cm)

WN = 025 ----- Number of depth cells (1-128)

WP = 00200 ----- Pings per Ensemble (0-16384)

WS = 0200 ----- Depth Cell Size (cm)

WV = 170 ----- Mode 1 Ambiguity Vel (cm/s radial)

TE = 00:15:00.00 ----- Time per Ensemble (hrs:min:sec.sec/100)

TF = **/**/**, **: **: ** --- Time of First Ping (yr/mon/day, hour:min:sec)

TP = 00:04.50 ----- Time per Ping (min:sec.sec/100)

TS = 11/08/06,19:42:10 --- Time Set (yr/mon/day, hour:min:sec)

EA = +00000 ----- Heading Alignment (1/100 deg)

EB = +00000 ----- Heading Bias (1/100 deg)

ED = 02850 ----- Transducer Depth (0 - 65535 dm)

ES = 32 ----- Salinity (0-40 pp thousand)

EX = 11111 ----- Coord Transform (Xform: Type,Tilts,3 Bm,Map)

EZ = 1111111 ----- Sensor Source (C,D,H,P,R,S,T)

Press any key to continue

CF = 11101 -----

Flow Ctrl (EnsCyc;PngCyc;Binry;Ser;Rec)

CK ----- Keep Parameters as USER Defaults

CR # ----- Retrieve Parameters (0 = USER, 1 = FACTORY)

CS ----- Start Deployment

>SYSTEM?

System Control, Data Recovery and Testing Commands:

AC ----- Output Active Fluxgate & Tilt Calibration data

AF ----- Field calibrate to remove hard/soft iron error

AR ----- Restore factory fluxgate calibration data

AX ----- Examine compass performance

AZ ----- Zero pressure reading

CB = 811 ----- Serial Port Control (Baud; Par; Stop)

CP # ----- Polled Mode (0 = NORMAL, 1 = POLLED)

CZ ----- Power Down Instrument

FC ----- Clear Fault Log

FD ----- Display Fault Log

OL ----- Display Features List

PA ----- Pre-Deployment Tests
PC1 ----- Beam Continuity
PC2 ----- Sensor Data
PS0 ----- System Configuration
PS3 ----- Transformation Matrices

RR ----- Recorder Directory
Press any key to continue RF -----
Recorder Space used/free (bytes)
RY ----- Upload Recorder Files to Host

>TS?
TS = 11/08/06,19:42:18 --- Time Set (yr/mon/day,hour:min:sec)

>PS0
Instrument S/N: 3694
Frequency: 614400 HZ
Configuration: 4 BEAM, JANUS
Match Layer: 10
Beam Angle: 20 DEGREES
Beam Pattern: CONVEX
Orientation: UP
Sensor(s): HEADING TILT 1 TILT 2 TEMPERATURE
Temp Sens Offset: -0.28 degrees C

CPU Firmware: 16.21 [0]
Boot Code Ver: Required: 1.13 Actual: 1.13
DEMOD #1 Ver: ad48, Type: 1f
DEMOD #2 Ver: ad48, Type: 1f
PWRTIMG Ver: 85d3, Type: 5

Board Serial Number Data:
C0 00 00 02 FB B2 24 09 CPU727-2000-00H
77 00 00 02 FB 7B 6A 09 DSP727-2001-03G
A4 00 00 02 FB 8C 65 09 PIO727-3000-03C
F4 00 00 02 FB 8E 9D 09 REC727-1000-03E

>PA

PRE-DEPLOYMENT TESTS

CPU TESTS:

RTC.....PASS
RAM.....PASS
ROM.....PASS

RECORDER TESTS:

PC Card #0.....NOT DETECTED
PC Card #1.....DETECTED
Card Detect.....PASS
Communication.....PASS
DOS Structure.....PASS
Sector Test (short).....PASS

DSP TESTS:

Timing RAM.....PASS
Demod RAM.....PASS
Demod REG.....PASS
FIFOs.....PASS

SYSTEM TESTS:

```

XILINK Interrupts... IRQ3  IRQ3  IRQ3 ...PASS
Receive Loop-Back.....PASS
Wide Bandwidth.....PASS
Narrow Bandwidth.....PASS
RSSI Filter.....PASS
Transmit.....PASS
SENSOR TESTS:
  H/W Operation.....***FAIL***
>PC2

```

Press any key to quit sensor display ...

Heading	Pitch	Roll	Up/Down	Attitude Temp	Ambient Temp	PRESSURE
167.22ø	27.32ø	5.95ø	Up	19.20øC	20.79øC	0.0
kPa167.40ø	27.33ø	5.76ø	Up	19.20øC	20.79øC	0.0
kPa167.76ø	27.32ø	5.60ø	Up	19.19øC	20.79øC	0.0
kPa167.82ø	27.33ø	5.48ø	Up	19.20øC	20.79øC	0.0
kPa168.12ø	27.32ø	5.35ø	Up	19.15øC	20.79øC	0.0
kPa167.99ø	27.33ø	5.45ø	Up	19.19øC	20.80øC	0.0
kPa167.80ø	27.33ø	5.51ø	Up	19.20øC	20.80øC	0.0

kPa

>RS

RS = 008,234 ----- REC SPACE USED (MB), FREE (MB)

>PC1

BEAM CONTINUITY TEST

When prompted to do so, vigorously rub the selected beam's face.

If a beam does not PASS the test, send any character to the ADCP to automatically select the next beam.

Collecting Statistical Data...

48	48	47	41	48	47	47	41	47	47	47	41	47	47	47	40	47	47	
47	40	47	47	47	40	47	47	46	40	47	47	46	40	47	47	46	40	47
47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40
47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46
40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47
46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47
47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40
47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46
40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47
46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47
47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40
47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46
40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47
46	40	47	47	46	40	47	47	46	40	47	47	46	40	47	47	46	40	47

Rub Beam 1 = PASS

Rub Beam 2 = PASS

Rub Beam 3 = PASS

Rub Beam 4 = PASS

>CZ

Powering Down

>>>>> Function starting 08/06/11 19:45:23 >>>>>

[BREAK Wakeup A]

WorkHorse Broadband ADCP Version 16.21

RD Instruments (c) 1996-2002

All Rights Reserved.

>DEPLOY?

Deployment Commands:

RE ----- Recorder ErAsE

RN ----- Set Deployment Name

WD = 111 100 000 ----- Data Out (Vel,Cor,Amp; PG,St,P0; P1,P2,P3)

WF = 0088 ----- Blank After Transmit (cm)

WN = 025 ----- Number of depth cells (1-128)

WP = 00200 ----- Pings per Ensemble (0-16384)

WS = 0200 ----- Depth Cell Size (cm)

WV = 170 ----- Mode 1 Ambiguity Vel (cm/s radial)

TE = 00:15:00.00 ----- Time per Ensemble (hrs:min:sec.sec/100)

TF = **/**/**, **: **: ** --- Time of First Ping (yr/mon/day, hour:min:sec)

TP = 00:04.50 ----- Time per Ping (min:sec.sec/100)

TS = 11/08/06,19:45:25 --- Time Set (yr/mon/day, hour:min:sec)

EA = +00000 ----- Heading Alignment (1/100 deg)

EB = +00000 ----- Heading Bias (1/100 deg)

ED = 02850 ----- Transducer Depth (0 - 65535 dm)

ES = 32 ----- Salinity (0-40 pp thousand)

EX = 11111 ----- Coord Transform (Xform: Type,Tilts,3 Bm,Map)

EZ = 1111111 ----- Sensor Source (C,D,H,P,R,S,T)

Press any key to continue

CF = 11101 -----

Flow Ctrl (EnsCyc;PngCyc;Binry;Ser;Rec)

CK ----- Keep Parameters as USER Defaults

CR # ----- Retrieve Parameters (0 = USER, 1 = FACTORY)

CS ----- Start Deployment

>SYSTEM?

System Control, Data Recovery and Testing Commands:

AC ----- Output Active Fluxgate & Tilt Calibration data

AF ----- Field calibrate to remove hard/soft iron error

AR ----- Restore factory fluxgate calibration data

AX ----- Examine compass performance

AZ ----- Zero pressure reading

CB = 811 ----- Serial Port Control (Baud; Par; Stop)

CP # ----- Polled Mode (0 = NORMAL, 1 = POLLED)

CZ ----- Power Down Instrument

FC ----- Clear Fault Log

FD ----- Display Fault Log

OL ----- Display Features List

PA ----- Pre-Deployment Tests

PC1 ----- Beam Continuity
PC2 ----- Sensor Data
PS0 ----- System Configuration
PS3 ----- Transformation Matrices

RR ----- Recorder Directory

Press any key to continue

RF -----

Recorder Space used/free (bytes)

RY ----- Upload Recorder Files to Host

>TS?

TS = 11/08/06,19:45:34 --- Time Set (yr/mon/day,hour:min:sec)

>PS0

Instrument S/N: 3694

Frequency: 614400 HZ

Configuration: 4 BEAM, JANUS

Match Layer: 10

Beam Angle: 20 DEGREES

Beam Pattern: CONVEX

Orientation: UP

Sensor(s): HEADING TILT 1 TILT 2 TEMPERATURE

Temp Sens Offset: -0.28 degrees C

CPU Firmware: 16.21 [0]

Boot Code Ver: Required: 1.13 Actual: 1.13

DEM0D #1 Ver: ad48, Type: 1f

DEM0D #2 Ver: ad48, Type: 1f

PWRTIMG Ver: 85d3, Type: 5

Board Serial Number Data:

C0 00 00 02 FB B2 24 09 CPU727-2000-00H

77 00 00 02 FB 7B 6A 09 DSP727-2001-03G

A4 00 00 02 FB 8C 65 09 PIO727-3000-03C

F4 00 00 02 FB 8E 9D 09 REC727-1000-03E

>PA

PRE-DEPLOYMENT TESTS

CPU TESTS:

RTC.....PASS

RAM.....PASS

ROM.....PASS

RECORDER TESTS:

PC Card #0.....NOT DETECTED

PC Card #1.....DETECTED

Card Detect.....PASS

Communication.....PASS

DOS Structure.....PASS

Sector Test (short).....PASS

DSP TESTS:

Timing RAM.....PASS

Demod RAM.....PASS

Demod REG.....PASS

FIFOs.....PASS

SYSTEM TESTS:

XILINX Interrupts... IRQ3 IRQ3 IRQ3 ...PASS

Receive Loop-Back.....PASS

```

Wide Bandwidth.....PASS
Narrow Bandwidth.....PASS
RSSI Filter.....PASS
Transmit.....PASS
SENSOR TESTS:
  H/W Operation.....PASS
>PC2

```

Press any key to quit sensor display ...

```

Heading  Pitch  Roll  Up/Down  Attitude Temp  Ambient Temp  PRESSURE
332.93ø -1.28ø -2.52ø  Up      19.45øC      21.02øC      0.0
kPa332.20ø -0.47ø -2.32ø  Up      19.43øC      21.03øC      0.0
kPa331.85ø -0.62ø -2.28ø  Up      19.44øC      21.02øC      0.0
kPa
>RS
RS = 000,242 ----- REC SPACE USED (MB), FREE (MB)
>PC1

```

BEAM CONTINUITY TEST

When prompted to do so, vigorously rub the selected beam's face.

If a beam does not PASS the test, send any character to the ADCP to automatically select the next beam.

```

Collecting Statistical Data...
 48 48 47 41 48 47 47 41 48 47 47 41 48 47 46 41 48 47
46 41 48 47 46 41 48 47 46 41 48 47 46 41 48 47 46 41 47
47 46 41 47 47 46 41 47 47 46 41 47 46 41 47 47 46 41 47
47 47 46 41 47 47 46 41 47 47 46 41 47 47 46 41 47 47 46
41 47 47 46 41 47 47 46 41 47 47 46 41 47 47 46 41 47 47
46 41 47 47 46 41 47 47 46 41 47 47 46 41 47 47 46 41 47
47 46 41 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40
47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46
40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47
46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47
47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40
47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46
40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47
46 40 47 47 46 40 47 47 46 40 47 47 46 40 47 47 46 40

```

```

Rub Beam 1 = PASS
Rub Beam 2 = PASS
Rub Beam 3 = PASS
Rub Beam 4 = PASS

```

>CZ

Powering Down

>>>>> Function starting 08/06/11 19:47:52 >>>>>

[BREAK Wakeup A]

WorkHorse Broadband ADCP Version 16.21

RD Instruments (c) 1996-2002

All Rights Reserved.

>CR1

[Parameters set to FACTORY defaults]

>CF11101

>EA0

>EB0

>ED2850

>ES32

>EX11111

>EZ1111111

>WB0

>WD111100000

>WF88

>WN29

>WP103

>WS200

>WV170

>TE00:05:00.00

>TP00:02.91

>TF11/08/07 01:00:00

>CK

[Parameters saved as USER defaults]

>The command CS is not allowed in this command file. It has been ignored.

>The following commands are generated by this program:

>CF?

CF = 11101 ----- Flow Ctrl (EnsCyc;PngCyc;Binry;Ser;Rec)

>CF11101

>RN 3694_

>CS

MicroCat SBE 37 Deployment Sheet

INSTRUMENT

Serial Number: 1537

Sensors (C,T,P): no pressure

Firmware Version: 2.6b

Depth Rating: lots

PARAMETERS

SampleNum: 0

Storetime: Y

Interval: 10 min

Syncmode: N

Navg/Ncycles: 4

Txrealtime: N

Reference pressure*: 325

OutputSV: N

Time Zone: UTC

OutputSal: Y

Start: August 7, 0100 UTC

*only needed if there is no pressure sensor for the salinity calculation

DEPLOYMENT

Station: Sogn-k

Cruise Number: 2011-60

Latitude: _____

Water Depth: _____

Longitude: _____

Instrument Depth: 325 m

Time and Date in Water: _____

Comments:

Fresh cal from factory.

Completed by: _____

Date: _____

uCat dep.xls SFM

Mooring: SOGN-K
UCats X 1
Serial 1537 - new cal, no pressure

Battery Calculations:

Sampling Time:

$$3.33s + (2.27 * (NAV G - 1))$$
$$3.33s + (2.27 * (4 - 1)) = 10.14s$$

Example 1: A standard MicroCAT (no external power option) with pressure sensor is set up to sample autonomously every 10 minutes (6 samples/hour), taking 4 measurement per sample (**NAV G=4**). How long can it be deployed?

Sampling time = 3.33 seconds + 2.27 seconds * (**NAV G** - 1) = 10.14 seconds

Sampling current consumption = 0.020 amps * 10.14 seconds = 0.2 amp-seconds/sample

In 1 hour, sampling current consumption = 6 * 0.2 amp-seconds/sample = 1.2 amp-seconds/hour

Pump current consumption = 0.13 amp-seconds/pulse

In 1 hour, pump current consumption = 6 * 0.13 amp-seconds/pulse = 0.78 amp-seconds/hour

Quiescent current 10 microamps = 0.01 mA

In 1 hour, quiescent current consumption = 0.01 mA * 3600 seconds/hour = 0.036 amp-seconds/hour

Total current consumption / hour = 1.2 + 0.78 + 0.036 = 2.02 amp-seconds/hour

Capacity = (5 amp-hours * 3600 seconds/hr) / (2.02 amp-seconds/hour) = 8910 hours = 371 days = 1.02 years

Number of samples = 8910 hours * 6 samples/hour = 53460 samples

Command Summary:

DDMMYY=060811

HHMMSS=160000 //(UTC)

OUTPUTSAL=Y

OUTPUTSV=Y

FORMAT=1

NAV G=4

PUMPINSTALLED=N

SAMPLENUM=0

INTERVAL=600

REFPRESS= 325 (x = pressure at which the instrument is at...only used if there is no pressure sensor installed)

STORETIME=Y
TXREALTIME=N
STARTDDMMYY=070811
STARTHHMMSS=010000
STARTLATER
